

The regulation forecast is subject to change daily as actual events occur.
Forecasted release reductions or increases are subject to change based on forecasted temperature and river conditions
and releases may be adjusted during winter freeze-in period. Intrasystem regulation may also require release adjustments.

		REGULATION FORECAST: 05/23/18																												
		FTPK				GARR				OAHE				BEND				FTRA				GAPT				SYSTEM				
		24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	GE	SG	DSG		
W	23	2243.1	35.0	17.0	3.84	1844.9	63.1	39.0	12.15	1610.9	42.8	38.5	11.71	1420.4	38.5	40.0	4.30	1357.9	46.0	38.9	5.39	1206.3	41.3	39.0	2.67	40.05	62391	104	W	23
T	24	2243.3	35.0	17.0	3.85	1845.1	65.1	39.0	12.16	1611.0	43.4	38.5	11.71	1420.3	38.5	40.0	4.29	1358.1	46.5	38.0	5.40	1206.6	41.5	38.0	2.68	40.08	62505	114	T	24
F	25	2243.4	35.0	17.0	3.85	1845.2	65.6	39.0	12.17	1611.0	43.9	38.5	11.71	1420.3	38.5	40.0	4.28	1358.3	47.0	38.0	5.40	1206.7	41.3	40.0	2.69	40.10	62617	112	F	25
	26	2243.6	35.0	17.0	3.85	1845.4	70.3	39.0	12.18	1611.0	43.9	34.0	10.36	1420.5	34.0	26.0	2.75	1358.1	33.4	38.0	5.40	1206.6	40.7	42.0	2.68	37.23	62735	118		26
	27	2243.7	35.0	17.0	3.85	1845.6	74.8	39.0	12.20	1611.1	43.9	32.0	9.76	1421.0	32.0	18.0	1.88	1357.8	25.1	38.0	5.39	1206.5	41.0	42.0	2.68	35.75	62861	126		27
M	28	2243.9	35.0	17.0	3.86	1845.8	80.0	39.0	12.21	1611.2	43.8	31.0	9.46	1420.9	31.0	34.0	3.64	1357.9	40.7	38.0	5.39	1206.4	41.0	42.0	2.67	37.23	62997	136	M	28
T	29	2244.0	37.0	17.0	3.86	1846.1	84.0	39.0	12.23	1611.2	43.8	35.0	10.67	1420.8	35.0	38.0	4.07	1358.0	44.3	38.0	5.39	1206.3	40.9	42.0	2.66	38.90	63144	147	T	29
W	30	2244.2	38.0	17.0	3.86	1846.4	87.0	39.0	12.25	1611.3	43.7	35.0	10.68	1420.7	35.0	38.0	4.07	1358.1	44.0	39.0	5.40	1206.2	40.9	42.0	2.66	38.91	63296	152	W	30
T	31	2244.4	38.0	17.0	3.87	1846.6	87.0	39.0	12.27	1611.3	43.7	35.0	10.68	1420.6	35.0	38.0	4.06	1358.2	43.9	39.0	5.40	1206.1	41.5	42.0	2.66	38.94	63449	153	T	31
F	1	2244.5	38.0	17.0	3.87	1846.9	85.0	39.0	12.29	1611.4	43.7	35.0	10.68	1420.5	35.0	38.0	4.06	1358.3	43.9	39.0	5.41	1206.1	41.8	42.0	2.65	38.96	63599	150	F	1
	2	2244.7	38.0	17.0	3.87	1847.1	82.0	39.0	12.30	1611.4	43.6	33.0	10.08	1420.6	33.0	30.0	3.19	1358.3	35.8	39.0	5.40	1206.1	41.8	42.0	2.65	37.50	63742	143		2
	3	2244.9	38.0	17.0	3.88	1847.4	81.0	39.0	12.32	1611.5	43.6	32.0	9.78	1421.0	32.0	20.0	2.10	1358.0	25.8	39.0	5.39	1206.0	41.8	42.0	2.65	36.12	63883	141		3
M	4	2245.1	37.0	17.0	3.88	1847.6	79.0	39.0	12.34	1611.6	43.5	35.0	10.69	1420.9	35.0	38.0	4.07	1358.1	43.7	39.5	5.40	1206.0	41.7	42.0	2.65	39.02	64017	134	M	4
T	5	2245.2	36.0	17.0	3.88	1847.8	77.0	39.0	12.35	1611.6	43.5	35.0	10.69	1420.8	35.0	38.0	4.07	1358.1	43.6	39.5	5.40	1206.0	42.0	42.0	2.65	39.04	64145	128	T	5
W	6	2245.4	35.0	17.0	3.88	1848.0	76.0	39.0	12.36	1611.6	43.4	35.0	10.70	1420.7	35.0	38.0	4.06	1358.2	43.6	39.5	5.40	1206.0	42.2	42.0	2.65	39.06	64269	124	W	6
T	7	2245.5	35.0	17.0	3.89	1848.2	75.0	39.0	12.38	1611.7	43.4	35.0	10.70	1420.6	35.0	38.0	4.06	1358.3	43.5	39.5	5.41	1206.0	42.1	42.0	2.65	39.08	64391	122	T	7
F	8	2245.6	34.0	17.0	3.89	1848.4	73.0	39.0	12.39	1611.7	43.3	35.0	10.70	1420.5	35.0	38.0	4.06	1358.4	43.5	39.5	5.41	1206.0	42.0	42.0	2.65	39.10	64507	116	F	8
	9	2245.8	33.0	17.0	3.89	1848.5	72.0	39.0	12.40	1611.8	43.3	33.0	10.10	1420.6	33.0	30.0	3.19	1358.3	35.4	39.5	5.41	1206.0	42.0	42.0	2.65	37.64	64618	111		9
	10	2245.9	32.0	17.0	3.89	1848.7	70.0	39.0	12.42	1611.9	43.2	32.0	9.80	1421.0	32.0	20.0	2.10	1358.0	25.3	40.0	5.39	1206.0	42.0	42.0	2.65	36.25	64723	104		10
M	11	2246.0	30.0	17.0	3.90	1848.9	67.0	39.0	12.43	1611.9	43.2	35.0	10.71	1420.9	35.0	38.0	4.07	1358.0	43.3	40.0	5.39	1206.0	42.3	42.0	2.65	39.15	64818	95	M	11
T	12	2246.1	29.0	17.0	3.90	1849.0	64.0	39.0	12.44	1611.9	43.1	35.0	10.71	1420.8	35.0	38.0	4.07	1358.1	43.2	39.5	5.40	1206.0	42.5	42.0	2.65	39.17	64906	88	T	12
W	13	2246.2	28.0	17.0	3.90	1849.1	61.0	39.0	12.45	1612.0	43.1	35.0	10.72	1420.7	35.0	38.0	4.07	1358.2	43.2	39.5	5.40	1206.0	42.2	42.0	2.65	39.18	64985	79	W	13
T	14	2246.3	26.0	17.0	3.90	1849.2	58.0	39.0	12.45	1612.0	43.1	35.0	10.72	1420.6	35.0	38.0	4.06	1358.3	43.1	39.5	5.40	1206.0	42.0	42.0	2.65	39.19	65054	69	T	14
F	15	2246.3	25.0	17.0	3.90	1849.3	55.0	39.0	12.46	1612.1	43.0	35.0	10.72	1420.5	35.0	38.0	4.06	1358.3	43.0	39.5	5.41	1206.0	42.0	42.0	2.65	39.20	65114	61	F	15

Project:		System:		Units:	
24EL	Midnight Elevation (feet above sea level)	GE	Daily Power Generation (1000 MWh)	kcfs	thousand cubic feet per second
24ID	Daily Average Inflow (kcfs)	SG	Midnight Storage (kAF)	MWh	megawatt hour
24OD	Daily Average Release (kcfs)	DSG	Daily Storage Change (kAF)	kAF	thousand acre feet
24GE	Daily Power Generation (1000 MWh)				

The midnight elevation (24EL) will be shown in color when a reservoir enters one of the following zones.
ex. 1234.5 - Exclusive Flood Control Zone (24EL)
ex. 1234.5 - Surcharge (24EL)